

## Our Water Quality Commitment:

### You Can Count on Washington Water Employees to . . .

- ⇒ provide you with the highest quality water possible
- ⇒ sample, test and treat your water on a regular basis
- ⇒ work diligently to meet every water quality standard on every system, every day
- ⇒ maintain water distribution system reliability
- ⇒ provide you with the highest level of customer service possible

#### Important Phone Numbers:

Washington Water Service Company  
P.O. Box 336  
Gig Harbor, WA 98335-0336  
Toll Free: (877) 408-4060  
<http://www.wawater.com>

NW Regional Operations Mgr:  
Dan Brown

Washington State Department of Health  
Northwest Office of Drinking Water  
20435- 72nd Avenue South Suite 200, K17-12  
Kent WA 98032-2358  
(253) 395-6750  
<http://www.doh.wa.gov/ehp/dw/>



WASHINGTON WATER  
SERVICE COMPANY

### Edgehill Water Association Water System State ID #22400P

## 2009 Drinking Water Report

Washington Water Service Company (WWSC) is committed to being a leader in providing communities and customers with traditional and innovative utility services. WWSC is proud of its service record and is staffed with courteous and knowledgeable water professionals who are dedicated to meeting your needs. While we are proud of our past record, we continually strive to improve upon the quality of services we provide to you, our valued customer.

This *2009 Drinking Water Report* is your annual update on the quality and safety of your drinking water. It includes the water quality monitoring results from the **most recent round** of testing done on your system, in accordance with state and federal regulations. This report also provides access through references and telephone numbers to source water assessments, health effects data and additional information about your water system. This allows you to make personal health-based decisions regarding your drinking water consumption and become more involved in decisions which may affect your health. We hope you find this information helpful.

**Washington Water Service Co.**  
Toll-free: (877) 408-4060

## Regarding “contaminants” in drinking water:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. In order to ensure that tap water is safe to drink, the Washington State Department of Health and EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) and the Washington Department of Agriculture regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

## Sources of drinking water:

Common sources of drinking water—both tap and bottled water—include rivers, lakes and streams (surface water) and wells and springs (groundwater). As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material. The water can also pick up substances resulting from the presence of animals or from human activity.

#### Reminder:

Any hazardous material that you put onto the ground or in your septic tank could potentially pollute the groundwater. Please help the Edgehill Water Assn Water System prevent groundwater contamination for this and future generations.

## Where does my water come from?

Your water comes from three active wells on the system and is considered groundwater. The water is pumped into the system from depths ranging from 53 to 161 feet. Your water is not treated (no chlorination, filtration, pH adjustment, etc).

## Contaminants that may be present in source water include:

- ◆ Microbial contaminants, such as viruses, parasites and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- ◆ Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- ◆ Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- ◆ Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- ◆ Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.



# Water Quality Data

## How To Read The Tables:

Your water is tested for more than 100 contaminants for which state and federal standards have been set. **Tables 1 & 2** list all primary contaminants that were detected (in any amount) along with their respective Maximum Contaminant Levels (MCLs). Primary standards protect public health by limiting the levels of these contaminants in drinking water. **Table 3** shows the levels of secondary contaminants and common water properties of interest to many consumers. Secondary contaminants have no known health effects but can affect the aesthetic properties of water (taste, odor and appearance). Secondary Maximum Contaminant Levels (SMCLs) are guidelines only.

## Terms and Abbreviations used:

**Maximum Contaminant Level (MCL):** the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):** the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL):** the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

**Lead and Copper 90th Percentile Value:** Out of every 10 homes sampled, 9 were at or below this level. This must be  $\leq$  the AL or additional steps must be taken.

**ppb:** parts per billion      **ppm:** parts per million  
**N/A:** not applicable

**Coliform Major Monitoring Violation.** The Edgehill Water Assn is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During the month of September 2008, we did not monitor or test for coliform bacteria and, therefore, cannot be sure of the quality of your drinking water during that time. This was an unfortunate oversight during transfer of water quality monitoring responsibility between former and current management. An “investigative” coliform sample was collected on 9/17/08 and was absent of coliforms. However, the Dept of Health cannot substitute investigative samples for routine compliance samples.

**TABLE 1: Primary Contaminants Detected In Your Drinking Water**

| Primary Contaminant | Units | Year Tested <sup>a</sup> | MCL | MCLG | YOUR WATER <sup>b</sup> | Compliant? (Y/N) | Major Sources in Drinking Water   |
|---------------------|-------|--------------------------|-----|------|-------------------------|------------------|---|
| Arsenic             | ppb   | 2007                     | 10  | 0    | 2 - 6                   | Y                | Erosion of natural rock formations (e.g., of volcanic rock origin in WA state); runoff from orchards; runoff from glass and electronics production wastes |

**TABLE 2: Lead and Copper Monitoring—Samples are collected at customer faucets. The number of homes sampled is based on population served by the system. Specific EPA-mandated criteria are used to select the homes:**

| Contaminant | Units | Year Tested <sup>a</sup> | AL  | No. of Homes Sampled | 90th Percentile Value | No. of Homes Exceeding the AL | Compliant? (Y/N) | Major Sources in Drinking Water                                      |
|-------------|-------|--------------------------|-----|----------------------|-----------------------|-------------------------------|------------------|--|
| Copper      | ppm   | 2006                     | 1.3 | 5                    | 0.02                  | 0                             | Y                | Corrosion of household plumbing systems; erosion of natural deposits |
| Lead        | ppb   | 2006                     | 15  | 5                    | < 2                   | 0                             | Y                | Corrosion of household plumbing systems; erosion of natural deposits |

**TABLE 3: Secondary and Unregulated Contaminants Detected in Your Drinking Water**

| Secondary Contaminant                       | Units | Year Tested <sup>a</sup> | SMCL             | YOUR WATER <sup>b</sup> | Compliant? (Y/N) | Major Sources in Drinking Water   |
|---|-------|--------------------------|------------------|-------------------------|------------------|---|
| Iron  | ppm   | 2007                     | 0.30             | < 0.1 - 0.64            | Y <sup>c</sup>   | Leaching from natural deposits; industrial wastes                                       |
| Manganese                                   | ppm   | 2007                     | 0.05             | 0.03 - 0.13             | Y <sup>c</sup>   | Leaching from natural deposits  |
| Sodium                                      | ppm   | 2007                     | N/A <sup>d</sup> | 5 - 6                   | Y                | Erosion of natural deposits; seawater influence   |
| Hardness                                    | ppm   | 2007                     | N/A              | 80 - 104 <sup>e</sup>   | Y                | Erosion of natural deposits   |
| <b>Unregulated Contaminants<sup>f</sup></b> |       |                          |                  |                         |                  |   |
| Lead  | ppb   | 2007                     | N/A              | < 2 - 7                 | Y                | Corrosion of plumbing systems and water distribution lines; erosion of natural deposits |

<sup>a</sup> Most recent testing done, in accordance with the regulations (required every 3 years).

<sup>b</sup> There are three active wells on this system and each is tested. A range of concentrations is shown if their results differ.

<sup>c</sup> Secondary maximum contaminant levels (SMCLs) are guidelines only, to control the staining and scale build-up on sinks and fixtures, and the “dirty”, colored water that nuisance minerals like iron and manganese can cause. There are no known health effects associated with drinking water containing iron and manganese at these levels.

<sup>d</sup> The EPA recommends 20 ppm sodium as a level of concern for consumers who must restrict their dietary intake.

<sup>e</sup> This is considered “soft” to “moderately hard” water and is equivalent to 4.7 - 6.1 grains per gallon of hardness. 0 - 75 ppm hardness is generally considered “soft” water, 75-150 ppm is “moderately hard”, 150-300 is “hard” and > 300 ppm is “very hard”.

<sup>f</sup> Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining their occurrence in drinking water and whether future regulation is warranted. There is currently no MCL for lead at the source (well). Lead and copper in drinking water most often come from corrosion of water distribution lines or household plumbing rather than from the water source itself. Therefore, EPA has established distribution system-related levels, called “action levels”, to control lead and copper (See Table 2 for these results).

**Arsenic.** Your drinking water currently meets EPA’s revised drinking water standard for arsenic. Each of the three active wells is well below the federal standard of 10 ppb (lowered from 50 ppb in January 2006). However, they do contain low levels of arsenic. There is a small chance that some people who drink water containing low levels of arsenic over many years could develop circulatory disease, cancer or other health problems. Most types of cancer and circulatory diseases are due to factors other than exposure to arsenic. EPA’s standard balances the current understanding of arsenic’s health effects against the costs of removing arsenic from drinking water.

The Office of Drinking Water has compiled **source water assessment program (SWAP) data** for all community water systems in Washington. SWAP data for your system is available by accessing DOH’s web site at:

<http://www4.doh.wa.gov/dw/swap/app/login.cfm?app=maps>

If you do not have access to the web, we encourage you to use the internet service available through the public library system.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised people such as those with cancer undergoing chemotherapy, those who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or by visiting their website. More information about contaminants found in water and their potential health effects can be found there, also.

**Safe Drinking Water Hotline**  
**1-800-426-4791**  
**www.epa.gov/ogwdw**